

CERTIFICATE

issued by

Rittal GmbH & Co. KG

Auf dem Stützelberg
D-35745 Herborn


Quality Management

Confirmation of protection class of KX enclosures:

1576000	1503000	1510000	1517000	1546000	1553000	1579000
1554000	1504000	1511000	1518000	1547000	1554000	1589000
1574000	1505000	1512000	1506000	1548000	1555000	
1575000	1506000	1513000	1527000	1549000	1556000	
1500000	1507000	1514000	1528000	1550000	1557000	
1501000	1508000	1515000	1529000	1551000	1577000	
1502000	1509000	1516000	1545000	1552000	1578000	

Above material numbers comply with the requirements of the Hosedown test according to UL 50 Type 4 (NEMA 4) and fulfil the protection category IP66 acc. to DIN EN 60529 "Degrees of protection provided by enclosures" dated September 2014.

Herborn, July 16, 2020



Jochen Schmidt
Quality Department

Rittal GmbH & Co. KG
Persönlich haltend:
Rittal Management GmbH,
Schwende

Management:
Dr.-Ing. Karl-Ulrich Köhler (CEO)
Dr. René Umlauf
Dr. Thomas Steffen
Andreas Huck
Carsten Röttchen
Uwe Scharf

Rittal GmbH & Co. KG
Auf dem Stützelberg
D-35745 Herborn
Phone: +49(0)27 72 5 05-0
Fax: +49(0)27 72 5 05-23 19
E-Mail: info@rittal.de
www.rittal.de
HRA 6126 Wetzlar

ENCLOSURES

POWER DISTRIBUTION

CLIMATE CONTROL

IT INFRASTRUCTURE

SOFTWARE & SERVICES

