

## IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

## CB TEST CERTIFICATE

## Product

Control cabinet cooling unit

## Name and address of the applicant

Rittal GmbH & Co.KG  
Auf dem Stützelberg, 35745 Herborn  
Germany

## Name and address of the manufacturer

Rittal GmbH & Co.KG  
Auf dem Stützelberg, 35745 Herborn  
Germany

## Name and address of the factory

Kelvin s.r.l  
Via Degli Imprenditori 15, 37067 Valeggio Sul Minco (VR)  
Italy*Note: When more than one factory, please report on page 2* Additional information on page 2

## Ratings and principal characteristics

380 – 480 V, 50 - 60 Hz  
2200 W (SK 3189940, SK3189340, SK 3189640, SK 3189945)  
1300 W (SK 3188940, SK 3188640, SK 3188945)  
1450 W (SK 3188340)

## Trademark / Brand (if any)



## Customer's Testing Facility (CTF) Stage used

CTF Stage 3

## Model / Type Ref.

Indoor models: SK 3189940 (5,8 kW); SK 3188940 (4,2 kW)  
Outdoor models: SK 3189340 (5,8 kW); SK 3188340 (4,2 kW)  
Stainless steel models: SK 3189640 (5,8 kW); SK 3188640 (4,2 kW)  
Chemical industry models: SK 3189945 (5,8 kW); SK 3188945 (4,2 kW)

## Additional information (if necessary may also be reported on page 2)

 Additional information on page 2

## A sample of the product was tested and found to be in conformity with

IEC 60335-1:2010, IEC 60335-1:2010/AMD1:2013, IEC 60335-1:2010/  
AMD2:2016, IEC 60335-2-40:2018

## National differences:

EU Group Differences, EU Special National Conditions

## As shown in the Test Report Ref. No. which forms part of this Certificate

35301236-001

This CB Test Certificate is issued by the National Certification Body

TÜV NORD CERT GmbH  
Am TÜV 1  
Essen, 45307  
Germany

TÜV NORD

Signature: Michael Eck

Date: 2023-05-30