

CERTIFICATE OF PRODUCT CERTIFICATION

TYPE II CQC CERTIFICATION

CERTIFICATE NO.: CQC2014010302718147

Valid from: Apr.02,2024

Valid until: Feb.28,2031

NAME AND REGISTERED ADDRESS OF THE APPLICANT Rittal GmbH & Co. KG
Auf dem Stützelberg, D-35745 Herborn, Germany

NAME AND REGISTERED ADDRESS OF THE MANUFACTURER Rittal GmbH & Co. KG
Auf dem Stützelberg, D-35745 Herborn, Germany

NAME AND LOCATION OF THE FACTORY EFEN GmbH
Gewerbepark Nord Nr.6,04938 Uebigau,Germany

PRODUCT NAME, MODEL AND SPECIFICATION Fuse-Switch-Disconnecter
SV9346.000、SV9346.010、SV9346.020、SV9346.030、SV9346.040; Ue : AC400V/500V/690V ;
Ie :160A ;Ui :1000V ;Uimp :8kV ;Ith :160A ;Iq :100kA ;Utilization Category :AC-22B(500V/690V)、
AC-23B(400V) ; Poles : 3P ; 50/60Hz.

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS GB/T 14048.3-2017

TYPE OF CERTIFICATION SCHEMES Type Testing of Product + Initial Factory Inspection + Follow up Factory Inspection

This is to certify that the above mentioned product(s) complies with the requirements of certification rules of CQC12-000001-2020.

Date of original issued: Sep.01,2020

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

The certificate information is available through the QR code below or CNCA's website: www.cnca.gov.cn



SIGN BY

郑士泉

SIGNATURE

谢肇煦



中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE

CHINA QUALITY CERTIFICATION CENTRE CO., LTD.
Section 9, No. 188, Nansihuan Xilu, Beijing 100070 P. R. China

Tel: +86 10 83886666
<http://www.cqc.com.cn>