

# CERTIFICATE OF COMPLIANCE

**Certificate Number** UL-CA-2133804-3  
**Report Reference** E76083-19810528  
**Date** 4-Dec-2023

**Issued to:** RITTAL GmbH & Co. KG  
Auf dem Stuetzelberg  
Herborn, Hessen 35745  
Germany

**This is to certify that  
representative samples of**

NITW7 - Industrial Control Panels Certified for Canada  
See Addendum Page for Product Designation(s).

Have been evaluated by UL in accordance with the  
Standard(s) indicated on this Certificate.

**Standard(s) for Safety:** CSA C22.2 NO. 14-18, 13th Ed., Issue Date: 2018-03-01

**Additional Information:** See the UL Online Certifications Directory at  
<https://iq.ulprospector.com> for additional information

This Certificate of Compliance indicates that representative samples of the product described in the certification report have met the requirements for UL certification. It does not provide authorization to apply the UL Mark. Only the Authorization Page that references the Follow-Up Services Procedure for ongoing surveillance provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.

*Deborah Jennings-Conner*

Deborah Jennings-Conner, VP Regulatory Services

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



# CERTIFICATE OF COMPLIANCE

**Certificate Number** UL-CA-2133804-3  
**Report Reference** E76083-19810528  
**Date** 4-Dec-2023

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements

<b>Model</b>	<b>Category Description</b>
Types AE and KL	Industrial Control Panel Enclosures
Types EB, JB, EB-EMC, EB-BUS, IE, and BG/BH, Bus Housings may be designated either BG (German) or BH (English).	Industrial Control Panel Enclosures

*Deborah Jennings-Conner*  
Deborah Jennings-Conner, VP Regulatory Services

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/about/locations/>



# CERTIFICATE OF COMPLIANCE

**Certificate Number** UL-US-2140329-3  
**Report Reference** E76083-19810528  
**Date** 4-Dec-2023

**Issued to:** RITTAL GmbH & Co. KG  
Auf dem Stuetzelberg  
Herborn, Hessen 35745  
Germany

**This is to certify that  
representative samples of**

NITW - Industrial Control Panels  
See Addendum Page for Product Designation(s).

Have been evaluated by UL in accordance with the  
Standard(s) indicated on this Certificate.

**Standard(s) for Safety:** UL 508A, 3rd Ed., Issue Date: 2018-04-24, Revision Date:  
2021-08-05

**Additional Information:** See the UL Online Certifications Directory at  
<https://iq.ulprospector.com> for additional information

This Certificate of Compliance indicates that representative samples of the product described in the certification report have met the requirements for UL certification. It does not provide authorization to apply the UL Mark. Only the Authorization Page that references the Follow-Up Services Procedure for ongoing surveillance provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.

*Deborah Jennings-Conner*

Deborah Jennings-Conner, VP Regulatory Services

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



# CERTIFICATE OF COMPLIANCE

**Certificate Number** UL-US-2140329-3  
**Report Reference** E76083-19810528  
**Date** 4-Dec-2023

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements

<b>Model</b>	<b>Category Description</b>
Types AE and KL	Industrial Control Panel Enclosures
Types EB, JB, EB-EMC, EB-BUS, IE, and BG/BH, Bus Housings may be designated either BG (German) or BH (English).	Industrial Control Panel Enclosures

*Deborah Jennings-Conner*  
Deborah Jennings-Conner, VP Regulatory Services

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/about/locations/>

