



Certificate of Compliance

Certificate: 1695572

Master Contract: 153184

Project: 70000080

Date Issued: March 18, 2013

Issued to: **Rittal GmbH & Co. KG**
Auf dem Stuetzelberg 18
Herborn, 35745
Germany
Attention: Rüdiger Gilardi

The products listed below are eligible to bear the CSA Mark shown



Nitin Bhople

Issued by: Nitin Bhople

PRODUCTS

CLASS 1211 02 - COMFORT CONDITIONING EQUIPMENT - Air Conditioning
Apparatus

Air conditioning apparatus, Series SK 3386 , models SK3386.140, .240, .540, SK 3386.640 rated 460V,60Hz, three phase. All with refrigerant R-134a. Design pressure 360 psig

Notes:

Notes (1): The air conditioning equipment to be used as a component part of another equipment, to cool electronic or mechanical components inside an electrical (enclosure) cabinet. The air conditioning unit, maintain a cabinet to a set temperature between 20°C to 55 °C. The unit will be operated within a maximum outdoor temperature ambient up to 55°C

APPLICABLE REQUIREMENTS

CAN/CSA-C22.2 No. 236-11 - Heating and Cooling Equipment

MARKINGS

As in report markings section.