

# CERTIFICATE

issued by

**Rittal GmbH & Co. KG**

Auf dem Stützelberg  
D-35745 Herborn

Quality Management

Hereby we confirm that the Rittal enclosures TS-IT

|          |          |
|----------|----------|
| 5507.130 | 5509.130 |
| 5514.130 | -        |

with screwing side panels TS 81XX.235 complies with the requirements of the atomized water test according to UL 50 Type 12 (NEMA 12) and fulfil the protection category IP55 according to EN 60529 "Degrees of protection provided by enclosures" dated September 2000.

Herborn, 2014-02-11

  
Axel Remmert  
Quality Management Laboratory



Rittal's test laboratory is accredited with the German Accreditation Council (DAkkS) No. D-PL-17086-01-01 and Underwriters Laboratories Inc.

Rittal GmbH & Co. KG  
Personally liable:  
Rittal Management GmbH,  
Schwende

Management:  
Friedhelm Loh (President)  
Karl Christoph Caselitz  
Dr. Guido Stannek  
Dr. Thomas Steffen  
Hermann Tetzner  
Michael Weiher

Rittal GmbH & Co. KG  
Auf dem Stützelberg  
D-35745 Herborn  
Phone: +49(0)27 72 5 05-0  
Fax: +49(0)27 72 5 05-23 19  
E-Mail: info@rittal.de  
www.rittal.de  
HRA 6126 Wetzlar

ENCLOSURES

POWER DISTRIBUTION

CLIMATE CONTROL

IT INFRASTRUCTURE

SOFTWARE & SERVICES

FRIEDHELM LOH GROUP

