

Rittal – The System.

Faster – better – everywhere.



The screenshot displays the RiZone software interface. On the left, a tree view shows the hierarchy: AC4DC > Rittal > Haiger > RiMatrixS > Container1 > Schrankreihe > Schrank1-7. The central panel shows a table of variables with columns for ID, Name, Value, Unit, and Maintenance group. The bottom panel is divided into two sections: 'Component' details for ID 20209 (LCP) and 'Live messages' log showing monitoring events with timestamps and descriptions.

ID	Name	Value	Unit	Maintenance group
20293	Water.Control-Valve.DescName	Control-Valve		Set
20294	Water.Control-Valve.ActualValue	66	%	
20296	Water.Control-Valve.Status	OK		
20501	Water.Cooling Capacity.DescName	Cooling-Capacity		Set
20502	Water.Cooling Capacity.Value	0	W	
20304	Water.Cooling Capacity.Status	OK		
20503	Water.Leakage Sensor.DescName	Leakage		Set
20301	Water.Leakage Sensor.Input	0		
20312	Water.Leakage Sensor.Status	OK		
20504	Water.Condensate Sensor.DescName	Condensate		Set
20505	Water.Condensate Sensor.Input	0		
20506	Water.Condensate Sensor.Pump	0		
20306	Water.Condensate Sensor.Cycles	0		
20307	Water.Condensate Sensor.Duration	0	s	
20316	Water.Condensate Sensor.Status	Off		
20310	Config.Fans.Command	Manual		Set
20311	Config.Control-Valve.Command	Manual		Set
20507	Config.Fans.Fan1	55	%	Set
20508	Config.Fans.Fan2	55	%	Set
20263	Config.Fans.Fan3	55	%	Set
20509	Config.Fans.Fan4	55	%	Set
20314	Config.Fans.Fan5	55	%	Set
20315	Config.Fans.Fan6	55	%	Set
20510	Config.Control-Valve.Valve	65	%	Set

Category filter on current list:	Show all messages categories from current list	Timespan filter on current list:	All	Status filter on current list:	
Timestamp	Elapsed time	Process	Owner	State	Description
(7) 6/27/2013 10:36:48 AM		Monitoring PU-T2 1963			
(3) 6/27/2013 10:36:48 AM		Monitoring R6_T_warm_mitte 11381			
(2) 6/27/2013 10:36:47 AM		Monitoring R6_T_warm_mitte 11381			
(5) 6/27/2013 10:35:44 AM	> 1 Min.	Monitoring LCP 20209			
(5) 6/27/2013 10:32:27 AM	> 4 Min.	Monitoring LCP 20209			
(1) 6/27/2013 10:16:38 AM	> 20 Min.	Monitoring LCP 20209			
(2) 6/27/2013 10:16:19 AM	> 20 Min.	Monitoring PU-LCP 2214			
(7) 6/27/2013 10:16:26 AM	> 22 Min.	Monitoring R6_L2_B_10591			

DK 7990.203

RiZone-Appliance Standard

Stato: 27/09/2024 (Fonte: rittal.com/it-it)

DK 7990.203 - RiZone-Appliance Standard

RiZone viene fornito come software-appliance.

Caratteristiche

Nr. d'ord.	DK 7990.203
Esecuzione	Software-Appliance: Software RiZone
Descrizione prodotto	RiZone è fornito come Software Appliance. Software Appliance è disponibile come server virtualizzato nel formato Open Virtualization Format (OVF), facilmente utilizzabile con l'hardware esistente nel data center.
Product modification	La RiZone Appliance viene fornita con la versione 3.5 di RiZone. Come sistema operativo viene supportato l'attuale sistema operativo Microsoft Server 2012R2. Il database locale utilizza SQL Express 2012.
Nota	RiZone supporta i protocolli SNMP V1/V2C e SNMP V3 per il monitoraggio dei componenti dell'infrastruttura (dispositivi OT) in un data center. RiZone è vendor-neutral e può essere utilizzato in un ambiente eterogeneo di dispositivi OT.
Confezione	1 pz.
Codice tariffa doganale	85234920
EAN	4028177665705
ETIM 7.0	EC000501
ECLASS 8.0	19240201